

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: CMO-Bjr/Inspection/2025-26/ 7803

Date: 24-11-2025

It is certified that an inspection team headed by Dr. Krishna Kant Rahul, Additional Chief Medical Officer Bijnor from Medical Health & Family Welfare Inspected THE HAZELMOON SCHOOL, Bijnor Road Chandpur, District Bijnor (U.P) dated on 22-11-2025 and found that THE HAZELMOON SCHOOL, Bijnor Road Chandpur, District Bijnor (U.P) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above certificate is valid for a period of ONE YEAR from issue date.

Signature with Seal:

Name: (Dr Krishna Kant Rahul)

Designation: (ACMO)

अपर मुख्य चिकित्सा अधिकारी
बिजनौर

To,

The Principal,

The Hazelmoon School,

Bijnor Road Chandpur,

District Bijnor.

(Name & Address of the Institution)

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Neeraj Kumar

(Name of Officers with designation) from Lab Attendant PHED

inspected the The Hazelmoon School, Bijner Road Chandpur

(Name & Address of the school) on 21/11/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. BS/1329 dated 22/11/2025

of District Level Water Analysis Laboratory (PHED Lab) certified that the

Bijner
The Hazelmoon School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

सहायक अभियन्ता

खण्ड कार्यालय

प्र० जल निगम (ग्रामीण)

बिजनौर

This certificate is valid till NA



Signature with Seal:

Name : SHUBHAM SAXENA

Designation : A.E.

Name & Address of the Office / Department :

To

THE HAZELMOON SCHOOL
BIJNER ROAD, CHANDPUR, P.O. RONIYA BIJNER
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Test Report

District Level Water Analysis Laboratory U.P., Jal Nigam Bijnor

Report No. 1339	5642/072 पी.सी.जी	Date	24.11.2025	Page No.	137
Office Name and Address		Customer Details			
Ref Letter No & date		THMS/1478/25-26		Date: 17-11-2025	
Basic details of sample					
District	Bijnor	Block	-----		
Gram Panchayat	-----	Village	-----		
Habitation	-----	Location	द हैजलमून स्कूल		
Water Source	सबमसिर्बल	Sample No.	BJ/1339		
Quantity of Sample	1 Lt	Date of S.C	21-11-2025		
Receiving Date	21-11-2025	Sample Collector	Neeraj Kumar		
Sample Depositor	Vishal	Sampling Method Used	IS 17614 (Part 1):2021		
Analysis Start Date	22-11-2025	Analysis Completion date-	22-11-2025		
Environmental Condition					
Temperature	23.6°C	Relative Humidity	Upto 56 %		

S.R	Analyzed Parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS 10500:2012		Ref Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.498	6.5-8.5	6.5-8.5	IS 3025 P-11:2022
2	Turbidity (NTU)	2.38	1.0	5.0	IS 3025 P-10:2023
3	TDS(mg/l)	292.0	500	2000	IS 3025 P-16:2023
4	Chloride(mg/l)	13.0	250	1000	IS 3025 P-32:2019
5	Total Alkalinity(mg/l)	200.0	200	600	IS 3025 P-23:2023
6	Total Hardness(mg/l)	236.0	200	600	IS 3025 P-21:2019
7	Calcium(mg/l)	52.09	75	200	IS 3025 P-40:2024
8	Magnesium (mg/l)	26.24	30	100	IS 3025 P-46:2023
9	Nitrate (mg/l)	0.85	45	45	Apha24 th edition -4500 NO ₃ ⁻ Method B (UV Screening Method):2023
10	Sulphate (mg/l)	3.26	200	400	Apha24 th edition-4500 SO ₄ ⁻ Method E (Turbidimetric Method):2023
11	Iron (mg/l)	0.06	1.0	1.0	Apha 24 th edition -3500 Fe method B (Phenanthroline Method):2023
12	Fluoride(mg/l)	0.254	1.0	1.5	Apha24th edition-4500 F ⁻ Method C (Electrode method):2023
13	E.coli	0	Shall not be detectable in 100 ml sample		IS 15185:2016
14	Total Coliform	0	Shall not be detectable in 100 ml sample		IS 15185:2016


Note -

- This Certificate refers only to the particular sample(s) submitted for testing.
- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
- The test results reported in this certificate are valid at the time of send under the stated conditions of measurements.
- Sample will be stored up to 7 days. (in case of non-perishable items only) from the date of issue of tests report unless.

Amit
Amit Kumar

prepared By: Lab Technician

Ankit
Ankit Kumar Gautam
Authorized Signatory
Technical Manager
(Microbiological)



End of Report